



Palliser Airshed Society - March 2013 Summary Report

Continuous Sampling Results - Crescent Heights Station


Pollutants		Month Records		24-Hour Records				1-Hour Records			
Name	Conc Unit	Avg. Conc.	Uptime	Maximum		AAAQO	Exceed	Maximum		AAAQO	Exceed
				Conc	Time	Objective	No.	Conc	Time	Objective	No.
SO ₂	ppb	0.4	100.0%	1.5	Mar-23	48	0	4.6	Mar-09 17:00	172	0
NO	ppb	2.2	100.0%	6.6	Mar-27	-	-	34.1	Mar-27 10:00	-	-
NO ₂	ppb	8.6	100.0%	14.6	Mar-25	-	-	39.1	Mar-10 0:00	159	0
NO _x	ppb	10.9	100.0%	20.2	Mar-25	-	-	64.9	Mar-10 0:00	-	-
O ₃	ppb	32	100.0%	46	Mar-31	-	-	60	Mar-30 15:00	82	0
CO	ppm	0.2	100.0%	0.3	Mar-25	-	-	0.6	Mar-25 8:00	13	0
THC	ppm	2.1	100.0%	2.4	Mar-8	-	-	2.8	Mar-08 8:00	-	-
PM _{2.5}	µg/m ³	11	97.4%	21	Mar-9	30	0	37	Mar-09 9:00	-	-



Instrument Uptime (%)




Wind Rose (km/hr)



Palliser Airshed Society - March 2013 Summary Report

Passive Sampling Results



Monthly Update

- * All data has been slope, intercept, and baseline corrected. Data may change after validation process.
- * The measured ambient concentrations of all parameters are within the AAAQO for the month of March 2013.
- * All compliance parameters are above 90% operational for the month of March 2013.
- * Routine calibration was performed on March 5, 2013.
- * The operational issues for the month of March include 1 hour of PM_{2.5} data flagged as maintenance during the filter change, and 18 hours of PM_{2.5} data flagged as analyzer failure, due to negative readings. 33 hours of wind speed and direction data are also flagged as analyzer failure on March 21-23. This failure is believed to be caused by ice/snow build-up on the wind sensor. The sensor returned to normal operations on March 23. A baseline shift has also occurred for the radiation sensor, AMEC is working on resolving this issue.